

CERTIFICATE OF COMPLIANCE

Certificate Number 20191119-R16640
Report Reference R16639
Issue Date 2019-November-19

Issued to: ISOLATEK INTERNATIONAL
41 Furnace St
Stanhope NJ 07874

**This certificate confirms that
representative samples of**

Intumescent Fire-resistive Materials
Type SprayFilm-WB 3 and Type WB 3
Type SprayFilm-WB 4 and Type WB 4
Type SprayFilm-WB 5 and Type WB 5

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 263, "Fire Tests of Building Construction and
Materials"

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

See addendum page 2.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191119-R16640
Report Reference R16639
Issue Date 2019-November-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Type SprayFilm-WB 3 and Type WB 3 coating investigated per the requirements of UL 263 for Interior General Purpose in Design Nos. D601, D902, D974, D976, D977, K918, N614, N635, X649, X650, Y614, Y622.

Type SprayFilm-WB 4 and Type WB 4 coating investigated per the requirements of UL 263 for Interior General Purpose in Design Nos. D601, D902, D976, D977, N614, N635, X649, X650, Y614, Y622.

Type SprayFilm-WB 4 and Type WB 4 coating investigated per the requirements of UL 263 for Exterior Use with Type SprayFilm TOPSEAL and Type TOPSEAL top coat in Design Nos. D601, D902, D976, D977, N614, N635, X649, X650, Y614, Y622. Type SprayFilm TOPSEAL and Type TOPSEAL top coat mixed 2.9:1 by weight ratio (2:1 by volume ratio) of Part A to Part B.

Type SprayFilm-WB 5 and Type WB 5 coating investigated per the requirements of UL 263 for Interior Conditioned Space and Interior General Purpose in Design Nos. D601, N634, Y615, . Y616, Y626.

Type WB 5 coating investigated per the requirements of UL 263 for Interior Conditioned Space and Interior General Purpose in Design Nos. D902.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

