

# BXUV.U706 - FIRE-RESISTANCE RATINGS - ANSI/UL 263

## Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

## BXUV - Fire Resistance Ratings - ANSI/UL 263 Certified for United States

## BXUV7 - Fire Resistance Ratings - CAN/ULC-S101 Certified for Canada

See General Information for Fire-resistance Ratings - ANSI/UL 263 Certified for United States  
Design Criteria and Allowable Variances

See General Information for Fire Resistance Ratings - CAN/ULC-S101 Certified for Canada  
Design Criteria and Allowable Variances


### **Design No. U706**

June 02, 2009

### **Exposed to Fire on Cementitious Face Only**

### **Nonbearing Wall Ratings — 1, 1-1/2, 2 or 3 Hr (See Item 5)**

**\* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**



1. **Supporting Angles** — 3-3/8 by 3-3/8 by 1/4 in. steel angles placed along top and bottom of wall, attached to masonry with 1/4 in. diam by 1-1/2 in. long nailable fasteners with lead plugs spaced 24 in. OC; 2 by 2 by 3/16 in. steel angles placed along sides of assembly, attached to masonry expansion shields spaced 5 ft OC.
2. **Flashing Angles** — Min No. 24 MSG galv steel formed into a Z profile with 1 and 1-1/2 in. legs and 2 in. web, located along top and bottom of wall, 1-1/2 in. leg attached to facing units. Angles attached to masonry with 1/4 in. diam by 1-1/2 in. long nailable fastener with lead plugs spaced 40 in. OC.
3. **Facing Units** — Min 0.020 in. thick (26 MSG) galv steel facing units with 1-1/2 in. deep flutes 6 in. OC. Panels fastened to support angles and reinforcing channel through flashing angles with 1/4 in. diam by 3/4 in. long self-tapping steel screws located in every flute in the horizontal direction.
4. **Reinforcing Channel** — C8 x 11.5 cold-rolled steel channel spaced 5 ft OC, attached to 2 by 2 by 3/16 in. steel angle with two 1/4 in. diam by 11/2 in. long bolts and nuts at each end. The angles were attached to side of masonry by two 5/16 in. diam by 21/2 in. long steel lag bolts with steel expansion shields at each end.
5. **Spray-Applied Fire Resistive Materials\*** — Prepared by mixing with water according to instructions on each bag of material and applied to reinforcing channel and one side of the wall, which must be free of dirt, oil or loose scale, to final thicknesses shown on the table below. Min avg and min ind density of 15 pcf for the Types 304 and 404. For method of density determination, refer to the General Design Information Section.

Classification Hr	Facing Unit	Mtl Thkns In. Reinforcing Channel
----------------------	-------------	--------------------------------------

1	1-5/8	1-1/8
1-1/2	2-5/16	1-3/8
2	2-11/16	1-5/8
3	3-1/16	2-1/8

**ISOLATEK INTERNATIONAL** — Types 304 and 404

**\* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2009-06-02

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"