



BYBU.XR739 - FIRE-RESISTANCE RATINGS - ANSI/UL 1709

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.


BYBU - Fire-resistance Ratings - ANSI/UL 1709

See General Information for Fire-resistance Ratings - ANSI/UL 1709

Design No. XR739

December 03, 2018

Ratings — 3/4, 1, 1-1/2, 2, 2-1/2, 3 or 4 Hr



1. **Steel Column** — Min size of column W8x10.

2. **Reinforcing Mesh** — No. 20 SWG galv steel wire twisted to form 1 or 2 in. hexagons. Mesh attached with steel helical pins or straight pins with washers 16 in. on center to the center of the column flanges and webs prior to application of Spray-Applied Fire Resistive Material. Mesh wrapped around the column and embedded at approximate mid-depth in Spray-Applied Fire Resistive Materials with a min. 3 inch overlap at vertical and horizontal joints.

2A. **Metal Lath** — (Not Shown) — In lieu of the reinforcing mesh, min 3.4 lb per sq. yd. expanded steel lath lapped 2 in. at joints and attached to column with power actuated fasteners and washers, spaced 18 in. OC at overlap.

3. **Spray-Applied Fire-Resistive Materials*** — See table below for appropriate thickness. Thickness measured to the steel column surface. Prepared by mixing with water according to instructions on each bag of mixture and spraying in one or more coats, as necessary, directly to the column through the reinforcing mesh, which must be clean and free of dirt, loose scale and oil. As an alternative to spraying, may be machine mixed and trowel applied. Min avg density of 753 kg/m³ (47 pcf), with min individual value of 689 kg/m³ (43 pcf). For method of density determination, see Design Information Section, Sprayed Material.

Min Required Thickness (inch) for Hourly Rating Period (min)

W/D	HP/A	45	60	90	120	150	180	240
0.33	406	7/8	1	1- 3/16	1-3/8	1-1/2	1-11/16	2-1/16
0.43	312	7/8	1	1- 3/16	1-3/8	1-1/2	1-11/16	2-1/16
0.57	235	7/8	1	1- 3/16	1-3/8	1-1/2	1-11/16	2-1/16
0.68	197	3/4	13/16	1	1-3/16	1-3/8	1-9/16	1-15/16
0.75	179	3/4	13/16	1	1-1/8	1-5/16	1-7/16	1-3/4
0.84	160	3/4	13/16	1	1-1/8	1-5/16	1-3/8	1-11/16
0.9	149	3/4	13/16	1	1-1/8	1-5/16	1-3/8	1-11/16
1	134	11/16	13/16	1	1-1/8	1-5/16	1-3/8	1-11/16
1.1	122	5/8	13/16	1	1-1/8	1-5/16	1-3/8	1-11/16
1.2	112	9/16	3/4	1	1-1/8	1-5/16	1-3/8	1-11/16
1.3	103	9/16	3/4	1	1-1/8	1-5/16	1-3/8	1-11/16
1.4	96	1/2	11/16	1	1-1/8	1-5/16	1-3/8	1-11/16
1.5	89	1/2	5/8	15/16	1-1/8	1-5/16	1-3/8	1-11/16
1.6	84	1/2	5/8	7/8	1-1/8	1-5/16	1-3/8	1-11/16
1.63	82	1/2	5/8	7/8	1	1-3/16	1-5/16	1-5/8
1.7	79	1/2	9/16	7/8	1	1-3/16	1-5/16	1-5/8
1.8	74	1/2	9/16	13/16	1	1-3/16	1-5/16	1-5/8
1.9	71	1/2	9/16	3/4	1	1-3/16	1-5/16	1-5/8
2	67	1/2	1/2	3/4	15/16	1-3/16	1-5/16	1-5/8
2.1	64	1/2	1/2	11/16	15/16	1-1/8	1-5/16	1-5/8
2.2	61	1/2	1/2	11/16	7/8	1-1/16	1-5/16	1-5/8
2.3	58	1/2	1/2	11/16	7/8	1-1/16	1-1/4	1-5/8
2.4	56	1/2	1/2	5/8	13/16	1	1-3/16	1-9/16
2.5	54	1/2	1/2	5/8	13/16	1	1-1/8	1-1/2
2.55	53	1/2	1/2	5/8	13/16	15/16	1-1/8	1-1/2

Min Required Thickness (mm) for Hourly Rating Period (min)

W/D	HP/A	45	60	90	120	150	180	240
-----	------	----	----	----	-----	-----	-----	-----

0.33	406	23	26	31	35	39	43	53
0.43	312	23	26	31	35	39	43	53
0.57	235	23	26	31	35	39	43	53
0.68	197	20	21	26	31	35	40	50
0.75	179	20	21	26	29	34	37	45
0.84	160	20	21	26	29	34	35	43
0.9	149	20	21	26	29	34	35	43
1	134	18	21	26	29	34	35	43
1.1	122	16	21	26	29	34	35	43
1.2	112	15	20	26	29	34	35	43
1.3	103	15	20	26	29	34	35	43
1.4	96	13	18	26	29	34	35	43
1.5	89	13	16	24	29	34	35	43
1.6	84	13	16	23	29	34	35	43
1.63	82	13	16	23	26	31	34	42
1.7	79	13	15	23	26	31	34	42
1.8	74	13	15	21	26	31	34	42
1.9	71	13	15	20	26	31	34	42
2	67	13	13	20	24	31	34	42
2.1	64	13	13	18	24	29	34	42
2.2	61	13	13	18	23	27	34	42
2.3	58	13	13	18	23	27	32	42
2.4	56	13	13	16	21	26	31	40
2.5	54	13	13	16	21	26	29	39
2.55	53	13	13	16	21	24	29	39

ISOLATEK INTERNATIONAL — Type M-II/P investigated for exterior use, and additionally evaluated for acid and solvent spray exposure.

GREENTECH THERMAL INSULATION PRODUCTS MFG CO L L C — Type M-II/P investigated for exterior use, and additionally evaluated for acid and solvent spray exposure.

NEWKEM PRODUCTS CORP — Type M-II/P investigated for exterior use, and additionally evaluated for acid and solvent spray exposure.

PERLITE ITALIANA SRL — Type M-II/P, investigated for exterior use, and additionally evaluated for acid and solvent spray exposure.

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2018-12-03

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"